

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

BAES of evacuation with light-emitting diode NP

Name and address of the applicant

LEGRAND FRANCE

128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX - FRANCE

Name and address of the manufacturer

LEGRAND FRANCE

128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX - FRANCE

Name and address of the factory

LEGRAND FRANCE.

1 RUE HENRI FREYSSINET
17140 LAGORD - FRANCE

Note: When more than one factory, please report on page 2

☐ Additional Information on page 2

Ratings and principal characteristics

230 V~; 50Hz ; class II ; IP 55 ; IK 07

Trademark (if any)

LEGRAND

Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

6 614 50, 6 614 51, 6 624 52, 6 614 53, 6 614 54, 6 614 55,
6 624 52

Additional information (if necessary may also be reported on page 2)

Supersedes CBTC FR_702402 dated 15/02/2018.
Update further to the evolution of the standard(s)
Remove a factory☒ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60598-1:2014+A1:2017
IEC 60598-2-22:2014+A1:2017


As shown in the Test Report Ref. No. which forms part of this Certificate

155321-720706 B,
155321-720707 B,
155321-720708 B

This CB Test Certificate is issued by the National Certification Body

LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr

Date: 05/09/2018

Signature: **Rém HANOT**
Certification Officer

ANNEX


References, ratings and main characteristics:

Bloc à Phares								
Référence	Désignation	Type BAES / LSC	Nbr d'accumulateurs	Caractéristiques batterie	Technologie	Fabricant	Autonomie (h)	Flux lumineux (lm)
6 614 50	BAP LEDS 600LM 1H NP STD	CTRL MANUEL	4	4Ah	NiCd	BST	1	600
6 614 51	BAP LEDS 900LM 1H NP STD	CTRL MANUEL	4	4Ah	NiCd	BST	1	900
6 614 52	BAP LEDS 1500LM 1H NP STD	CTRL MANUEL	4	4Ah	NiCd	BST	1	1500
6 614 53	BAP LEDS 2500LM 1H NP STD	CTRL MANUEL	6	4Ah	NiCd	BST	1	2500
6 624 52	BAP LEDS 1500LM 1H NP ADR LVS2	SATI ADR	4	4Ah	NiCd	BST	1	1500
6 614 54	BAP LEDS 1000LM 2H NP STD	CTRL MANUEL	4	4Ah	NiCd	BST	2	1000
6 614 55	BAP LEDS 600LM 3H NP STD	CTRL MANUEL	4	4Ah	NiCd	BST	3	600



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr

Date: 05/09/2018



Signature: Rémi HANOT
Certification Officer