

ASSOCIAZIONE PER LA CERTIFICAZIONE DELLE APPARECCHIATURE ELETTRICHE

Via Tito Livio, 5 - 24123 - BERGAMO (Italy)

tel. +390354175244 fax. +390354534662e-mail: acaecert@tin.it



## Certificate of Conformity

LOVAG-Certificate No. IT 05.041

## **Apparatus**

Low voltage swithchgear assembly - 3 phases + neutral - 400 V (U) -690 V (U, ) - 4 kV (U, ) - 125 A (I, ) - 10 kA (I, ) - frequency 50 Hz

This Certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designation with that tested rests with the manufacturer or responsible vendor.

This certificate has been prepared according to LOVAG (Low Voltage Agreement Group) Objectives and Operating Principles of mutual recognition. The responsible certification body as member of LOVAG issues a Certificate of Conformity with the above mentioned Standard(s) following the exclusive use of LOVAG Test instructions wherever applicable

Only integral reproduction of this Certificate or reproductions of this page accompanied by any page(s) on which are stated the tests performed and the assigned rated characteristics of the apparatus tested, are permitted without written permission from the LOVAG Signatory responsible for this Certificate.

## Designation

XL3 160 (encastrè / flush mounted) arrangement 31

## Manufacturer or responsible vendor

Legrand S.A.- 128, Av. du Marèchal-de-Lattre-de-Tassigny -87045 Limoges Cedex (France)

Tested for: Legrand S.A.

Tested by: ACAE Laboratory IB 01

The apparatus, constructed in accordance with the description mentioned in the Test Report listed on this Certificate has been subjected to the senes of proving tests in accordance with IEC/EN 60439-1:1999, amendment 1:2004

8.2.1.3 Temperature-rise test using current on all appartus

The results are shown in the Test Report in accordance to LOVAG. The values obtained and the general performance are considered to comply with the above Standard(s) and to justify the characteristic assigned by the manufacturer as stated below.

Incoming circuit: 125 A (I<sub>a</sub>) Diversity factor: 0.88

Outgoing circuits: 10 A (I<sub>z</sub>) Diversity factor: 0.46

This document includes Report No.: 05.099

Issue Date: 2005.10.21

Responsible Certification Body: ACAE

Authorized Signature

Date: 2005,11,14

Signatory of £ A and (AF Mutual Recognition Agreement)

