

Certificate number: 05348/G0 BV File number: ACE 02/062/02

Product code: 2645H

This certificate is not valid when presented without the full attached schedule composed of 7 sections

www.veristar.com

# TYPE APPROVAL CERTIFICATE

This certificate is issued to

### **LEGRAND FRANCE-LIMOGES**

**LIMOGES - FRANCE** 

for the type of product

# **FUSES / FUSES COMBINATION UNITS (LOW VOLTAGE)**

Fuse Disconnectors SP 51.

#### Requirements:


BV Rules for the Classification of Steel Ships. IEC 60269-2/2-1.

This certificate is issued to attest that BUREAU VERITAS did undertake the relevant approval procedures for the product identified above which was found to comply with the relevant requirements mentioned above.

This certificate will expire on: 28 Feb 2018

#### For BUREAU VERITAS,

At BV BORDEAUX, on 28 Feb 2013, Raphael Garnier





This certificate remains valid until the date stated above, unless cancelled or revoked, provided the conditions indicated in the subsequent page(s) are complied with and the product remains satisfactory in service. This certificate will not be valid if the applicant makes any changes or modifications to the approved product, which have not been notified to, and agreed in writing with BUREAU VERITAS. Should the specified regulations or standards be amended during the validity of this certificate, the product(s) is/are to be re-approved prior to it/they being placed on board vessels to which the amended regulations or standards apply. This certificate is issued within the scope of the General Conditions of BUREAU VERITAS Marine Division available on the internet site www.veristar.com. Any Person not a party to the contract pursuant to which this document is delivered may not assert a claim against BUREAU VERITAS for any liability arising out of errors or omissions which may be contained in said document, or for errors of judgement, fault or negligence committed by personnel of the Society or of its Agents in establishment or issuance of this document, and in connection with any activities for which it may provide.

# THE SCHEDULE OF APPROVAL

## 1. PRODUCT DESCRIPTION:

Product	Number of	Rated voltage	Maximum operating	Remarks
Type	poles	( <b>V</b> )	current (A)	
Fuse				
Disconnectors				With or without
SP 51	1 to 4	400	50	micro- switch.
		500	50	
		690	25	Used with fuses
				aM or gG 14 x 51
				with or without
Ref:				striker.
21500 to 21505				
21533 -				Accessories Ref:
21536 -				-21696
				-21695
				-21692
				-21698

### 2. DOCUMENTS AND DRAWINGS:

According to catalogue 2007.

### 3. TEST REPORTS:

Laboratoire d'essais LEGRAND.

Test reports N°:

- S 00018.61.1 and S 00018.63.1 dated 18/07/2001.
- S00111.9.1 dated 31/08/06

#### 4. APPLICATION / LIMITATION:

According to BV Rules for the Classification of Steel Ships.

### **5. PRODUCTION SURVEY REQUIREMENTS:**

- 5.1 The above products are to be supplied by **LEGRAND FRANCE** in accordance with the type described in this certificate and Bureau Veritas Rules for the Classification of Steel Ships.
- 5.2 This type of product is within the category HBV of Bureau Veritas Rule Note NR320.
- 5.3 **LEGRAND FRANCE** has to make the necessary arrangements to have its works recognised by Bureau Veritas in compliance with the requirements of NR320 for HBV products:

LEGRAND FRANCE-Strasbourg 290 Avenue de Colmar - BP 101 67024 CEDEX 1 - Strasbourg FRANCE

### **6. MARKING OF PRODUCT:**

According to IEC 60269-2/2-1 specifications.

#### 7. OTHERS:

- 7.1 This approval is given with the understanding that the Society reserves the right to require check tests to be carried out on the units at any time and that **LEGRAND FRANCE** (**LIMOGES FRANCE**) will accept full responsibility for informing shipbuilders, shipowners or their sub-contractors of the proper methods of use and general maintenance of the units and the conditions of this approval.
- 7.2 This Certificate supersedes the Type Approval Certificate N° 05348/F0 BV issued on 01/10/2007 by the Society.

\*\*\* END OF CERTIFICATE \*\*\*