

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Box for accessories

Name and address of the applicant

LEGRAND FRANCE

128, avenue du Maréchal de Lattre de Tassigny B.P. 523
87045 LIMOGES CEDEX - France

Name and address of the manufacturer

LEGRAND FRANCE

128, avenue du Maréchal de Lattre de Tassigny B.P. 523
87045 LIMOGES CEDEX - France

Name and address of the factory

LEGRAND MAGYARORSZAG VILLAMOSSAGI RENDSZEREK ZRT

Ipartelepi ut 14 pf 10
6600 SZENTES - Hungary

Note: When more than one factory, please report on page 2

 Additional Information on page 2

Ratings and principal characteristics

450 V~, IP40 ; 850°C
see Annex

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

ECOBATIBOX series

Références : Voir Annexe / See Annex

Additional information (if necessary may also be reported on page 2)

 Additional Information on page 2


A sample of the product was tested and found to be in conformity with

IEC 60670-1:2002(ed.1) +A1:2011

As shown in the Test Report Ref. No. which forms part of this Certificate

147883-701669

This CB Test Certificate is issued by the National Certification Body

LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr

Date: 05/05/2017

Signature: **Jean-François BRUEL**
Certification Officer

ANNEX

References, ratings and main characteristics:

References Mechanism	Capacity		Depth (mm)	Diameter axes (mm)	Between axes (mm)
	gang	modules			
0 800 07	1	-	40	67	-
0 800 12	1	-	40	67	-
0 800 13	1	-	50	67	-
0 800 14	1	-	50	67	-
0 800 21	1	-	40	67	-
0 800 22	2	5	40	67	71
0 800 23	3	8	40	67	71
0 800 24	4	10	40	67	71
0 800 31	1	-	50	67	-
0 800 32	2	5	50	67	71
0 800 33	3	8	50	67	71
0 800 34	4	10	50	67	71
0 800 84	1	-	40	85	-
0 800 86	1	-	40	85	-
0 905 00	1	-	50	67	-
0 905 08	1	-	40	67	-
0 905 09	2	5	40	67	71
0 905 10	3	8	40	67	71
0 905 22	4	10	40	67	71

Rated insulation voltage	450 V~
Nature of material	Insulating material
Method of installation	Flush in :
	Hollow walls, hollow ceilings, hollow floors or furniture
	Placement :
	Placement: Suitable for all types of installation except into concrete
Type of inlets (outlets)	With inlets for plain or corrugated conduits
Clamping means	Without clamping means
Minimum and maximum temperatures during installation	De -5°C à +60°C / From -5°C to +60°C
Boxes and enclosures for hollow walls and the like	Degree of protection of the part mounted in the hollow wall : IP40
Arrangements to fix the accessories to the boxes	Boxes fitted out with screws, Boxes destined to receive another fixing means
Glow-wire test made at	850 °C


Accessories / Sealing air cap for conduit

Reference	Diameter (mm)	Color	Trade mark
0 905 17	16	grey	Legrand
0 905 18	20	grey	
0 905 19	25	grey	
05916	16	blue	Arnould
05917			
05920			
05921	20	blue	
05925			
05926			
05932	25	blue	
05933			

For more information relating to the ratings and the main characteristics please refer to the CB Test Report: 147883-701669



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr



LABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES
S.A.S au capital de 150745000 €
RCS Nanterre 8408/83174
33 Avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSES

Date: 05/05/2017

Signature: **Jean-François BRUEL**
Certification Officer