



ASSOCIAZIONE PER LA CERTIFICAZIONE
DELLE APPARECCHIATURE ELETTRICHE



Via Tito Livio, 5 - 24123 - BERGAMO (Italy)

tel. +390354175244 fax +390354534662 e mail: acaecert@tin.it

Certificate of Conformity

LOVAG-Certificate No. IT 06.051

Apparatus

Low voltage switchgear assembly - 3 phases + neutral - 400 V (U_n) - 690 V (U_i) - 8 kV (U_{imp}) - 4000 A (I_n) - 50 kA (I_{cc}) - frequency 50/60Hz

Designation

XL3 4000 Arrangement 19

Manufacturer or responsible vendor

Legrand S.A. - 128, Av. du Maréchal-de-Lattre-de-Tassigny - 87045 Limoges Cedex (France)

Tested for: Legrand S.A.

Tested by: ACAE Laboratory IB 01

The apparatus, constructed in accordance with the description mentioned in the Test Report listed on this Certificate has been subjected to the series of proving tests in accordance with IEC/EN 60439-1:1999; amendment 1:2004

8.2.1 Verification of temperature-rise limits using current on all apparatus

The results are shown in the Test Report in accordance to LOVAG. The values obtained and the general performance are considered to comply with the above Standard(s) and to justify the characteristic assigned by the manufacturer as stated below.

Incoming circuit: 3200 A (I_n)
Diversity factor 0,80

Outgoing circuit: 1067 A (I_n)
Diversity factor 0,67

This document includes Report No : 06.079
Issue Date: 2006.10.02

Responsible Certification Body: ACAE

Mauro Marchi

Authorized Signature

Date: 2006.12.11

SINCERT

ACCREDITAMENTO ORGANISMO DI CERTIFICAZIONE E SPERIMENTAZIONE

PRD N°070B

Signatory of EA and IAF Mutual Recognition Agreements

This Certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designation with that tested rests with the manufacturer or responsible vendor.

This certificate has been prepared according to LOVAG (Low Voltage Agreement Group) Objectives and Operating Principles of mutual recognition. The responsible certification body as member of LOVAG issues a Certificate of Conformity with the above mentioned Standard(s) following the exclusive use of LOVAG Test Instructions wherever applicable.

Only integral reproduction of this Certificate or reproductions of this page accompanied by any page(s) on which are stated the tests performed and the assigned rated characteristics of the apparatus tested, are permitted without written permission from the LOVAG Signatory responsible for this Certificate.

