

# AENOR

## AENOR Product Certificate Low Voltage Material



030/002274

AENOR certifies that the organization

### LEGRAND GROUP ESPAÑA, S.L.

registered office CL HIERRO, 56 28850 TORREJON DE ARDOZ (Madrid - España)

supplies Residual current operated circuit-breakers with integral overcurrent protection for household and similar uses(RCBO's)

in compliance with  
UNE-EN 61009-1:2013 (EN 61009-1:2012)  
UNE-EN 61009-1:2013/A11:2016 (EN 61009-1:2012/A11:2015)  
UNE-EN 61009-1:2013/A1:2015 (EN 61009-1:2012/A1:2014)  
UNE-EN 61009-1:2013/A12:2016 (EN 61009-1:2012/A12:2016)  
UNE-EN 61009-1:2013/A2:2015 (EN 61009-1:2012/A2:2014)  
UNE-EN 61009-2-1/A11:1999 (EN 61009-2-1/A11:1998)  
UNE-EN 61009-2-1:1996 (EN 61009-2-1:1994)

References Specified in Annex to the Certificate

Production site PARC INTERNATIONAL DE SOPHIA-ANTIPOLIS ANTIBES CEDEX (Francia)

Certification scheme In order to grant this Certificate, AENOR has tested the product and has verified the quality system implemented for its manufacture. AENOR performs these tasks periodically while the Certificate has not been cancelled, in accordance with Specific Rules RP 030.15.

This certificate supersedes 030/002274, dated 2015-04-15

First issued on 2012-01-13  
Modified on 2017-07-04  
Validity date 2021-01-13

Rafael GARCÍA  
General Manager

Original Electrónico

# AENOR

## AENOR Product Certificate Low Voltage Material

030/002274

### Annex to Certificate

Trade mark: LEGRAND

Type Ref.	No. of poles	Rated current	Rated voltage	Rated residual operating current	Rated short-circuit capacity	Rated residual making and breaking capacity	Tripping	Type	Energy limiting class	Additional information
4111 85	4P	10 A	400 V-	30 mA	6000 A	4500 A	C	AC	3	(1)
4111 86	4P	16 A	400 V-	30 mA	6000 A	4500 A	C	AC	3	(1)
4111 87	4P	20 A	400 V-	30 mA	6000 A	4500 A	C	AC	3	(1)
4111 88	4P	25 A	400 V-	30 mA	6000 A	4500 A	C	AC	1	(1)
4111 89	4P	32 A	400 V-	30 mA	6000 A	4500 A	C	AC	1	(1)
4112 04	4P	10 A	400 V-	300 mA	6000 A	4500 A	C	AC	3	(1)
4112 05	4P	16 A	400 V-	300 mA	6000 A	4500 A	C	AC	3	(1)
4112 06	4P	20 A	400 V-	300 mA	6000 A	4500 A	C	AC	3	(1)
4112 07	4P	25 A	400 V-	300 mA	6000 A	4500 A	C	AC	1	(1)
4112 08	4P	32 A	400 V-	300 mA	6000 A	4500 A	C	AC	1	(1)
4112 33	4P	10 A	400 V-	30 mA	6000 A	4500 A	C	A	3	(1)
4112 34	4P	16 A	400 V-	30 mA	6000 A	4500 A	C	A	3	(1)
4112 35	4P	20 A	400 V-	30 mA	6000 A	4500 A	C	A	3	(1)
4112 36	4P	25 A	400 V-	30 mA	6000 A	4500 A	C	A	1	(1)
4112 37	4P	32 A	400 V-	30 mA	6000 A	4500 A	C	A	1	(1)
4112 38	4P	10 A	400 V-	300 mA	6000 A	4500 A	C	A	3	(1)
4112 39	4P	16 A	400 V-	300 mA	6000 A	4500 A	C	A	3	(1)
4112 40	4P	20 A	400 V-	300 mA	6000 A	4500 A	C	A	3	(1)
4112 41	4P	25 A	400 V-	300 mA	6000 A	4500 A	C	A	1	(1)
4112 42	4P	32 A	400 V-	300 mA	6000 A	4500 A	C	A	1	(1)

(1) These circuit-breakers (RCBO'S) are for ambient air temperature from -25°C to 40°C

First issued on 2012-01-13  
Modified on 2017-07-04  
Validity date 2021-01-13

Original Electrónico

AENOR INTERNACIONAL S.A.U.  
Génova, 6. 28004 Madrid. España  
Tel. 91 432 60 00.- www.aenor.com

# AENOR

## AENOR Product Certificate Low Voltage Material



030/002274

AENOR certifies that the organization

### LEGRAND GROUP ESPAÑA, S.L.

registered office CL HIERRO, 56 28850 TORREJON DE ARDOZ (Madrid - España)

supplies Residual current operated circuit-breakers with integral overcurrent protection for household and similar uses(RCBO's)

in compliance with  
UNE-EN 61009-1:2013 (EN 61009-1:2012)  
UNE-EN 61009-1:2013/A11:2016 (EN 61009-1:2012/A11:2015)  
UNE-EN 61009-1:2013/A1:2015 (EN 61009-1:2012/A1:2014)  
UNE-EN 61009-1:2013/A12:2016 (EN 61009-1:2012/A12:2016)  
UNE-EN 61009-1:2013/A2:2015 (EN 61009-1:2012/A2:2014)  
UNE-EN 61009-2-1/A11:1999 (EN 61009-2-1/A11:1998)  
UNE-EN 61009-2-1:1996 (EN 61009-2-1:1994)

References Specified in Annex to the Certificate

Production site PARC INTERNATIONAL DE SOPHIA-ANTIPOLIS ANTIBES CEDEX (Francia)

Certification scheme In order to grant this Certificate, AENOR has tested the product and has verified the quality system implemented for its manufacture. AENOR performs these tasks periodically while the Certificate has not been cancelled, in accordance with Specific Rules RP 030.15.

This certificate supersedes 030/002274, dated 2015-04-15

First issued on 2012-01-13  
Modified on 2017-07-04  
Validity date 2021-01-13

Rafael GARCÍA  
General Manager

Original Electrónico

# AENOR

## AENOR Product Certificate Low Voltage Material

030/002274

### Annex to Certificate

Trade mark: LEGRAND

Type Ref.	No. of poles	Rated current	Rated voltage	Rated residual operating current	Rated short-circuit capacity	Rated residual making and breaking capacity	Tripping	Type	Energy limiting class	Additional information
4111 85	4P	10 A	400 V-	30 mA	6000 A	4500 A	C	AC	3	(1)
4111 86	4P	16 A	400 V-	30 mA	6000 A	4500 A	C	AC	3	(1)
4111 87	4P	20 A	400 V-	30 mA	6000 A	4500 A	C	AC	3	(1)
4111 88	4P	25 A	400 V-	30 mA	6000 A	4500 A	C	AC	1	(1)
4111 89	4P	32 A	400 V-	30 mA	6000 A	4500 A	C	AC	1	(1)
4112 04	4P	10 A	400 V-	300 mA	6000 A	4500 A	C	AC	3	(1)
4112 05	4P	16 A	400 V-	300 mA	6000 A	4500 A	C	AC	3	(1)
4112 06	4P	20 A	400 V-	300 mA	6000 A	4500 A	C	AC	3	(1)
4112 07	4P	25 A	400 V-	300 mA	6000 A	4500 A	C	AC	1	(1)
4112 08	4P	32 A	400 V-	300 mA	6000 A	4500 A	C	AC	1	(1)
4112 33	4P	10 A	400 V-	30 mA	6000 A	4500 A	C	A	3	(1)
4112 34	4P	16 A	400 V-	30 mA	6000 A	4500 A	C	A	3	(1)
4112 35	4P	20 A	400 V-	30 mA	6000 A	4500 A	C	A	3	(1)
4112 36	4P	25 A	400 V-	30 mA	6000 A	4500 A	C	A	1	(1)
4112 37	4P	32 A	400 V-	30 mA	6000 A	4500 A	C	A	1	(1)
4112 38	4P	10 A	400 V-	300 mA	6000 A	4500 A	C	A	3	(1)
4112 39	4P	16 A	400 V-	300 mA	6000 A	4500 A	C	A	3	(1)
4112 40	4P	20 A	400 V-	300 mA	6000 A	4500 A	C	A	3	(1)
4112 41	4P	25 A	400 V-	300 mA	6000 A	4500 A	C	A	1	(1)
4112 42	4P	32 A	400 V-	300 mA	6000 A	4500 A	C	A	1	(1)

(1) These circuit-breakers (RCBO'S) are for ambient air temperature from -25°C to 40°C

First issued on 2012-01-13  
Modified on 2017-07-04  
Validity date 2021-01-13

Original Electrónico

AENOR INTERNACIONAL S.A.U.  
Génova, 6. 28004 Madrid. España  
Tel. 91 432 60 00.- www.aenor.com