

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Switch for fixed electrical installation

Name and address of the applicant

LEGRAND FRANCE

128, avenue du Maréchal de Lattre de Tassigny B.P. 523,
87045 LIMOGES CEDEX - France

Name and address of the manufacturer

LEGRAND FRANCE

128, avenue du Maréchal de Lattre de Tassigny B.P. 523,
87045 LIMOGES CEDEX - France

Name and address of the factory

LEGRAND FRANCE

128, avenue du Maréchal de Lattre de Tassigny B.P. 523,
87045 LIMOGES CEDEX - France

Note: When more than one factory, please report on page 2

 Additional Information on page 2

Ratings and principal characteristics

6 A, 10 AX, 16 AX, 250 V~, IP55

Trademark (if any)

LEGRAND

Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

SOLIROC series

References:

0 778 11, 0 778 12, 0 778 13, 0 778 14, 0 778 21,
0 778 22, 0 778 41, 0 778 42, 0 778 43, 0 778 44

Additional information (if necessary may also be reported on page 2)

Supersedes CBTC 569883C/A2 dated 24/09/2015. Addition of
factory(ies) Additional Information on page 2


A sample of the product was tested and found to be in conformity with

IEC 60669-1:1998(ed.3) +A1:1999 +A2:2006

As shown in the Test Report Ref. No. which forms part of this Certificate

130899-663536Cr2016-10-05, 132235-666597A, 80701-
569886, 135049-671321A, 146030-698305

This CB Test Certificate is issued by the National Certification Body

LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr

Date: 06/02/2017

Signature: Gilles LEMONNIER
Certification Officer

ANNEX

Name and address of the factories:

 LEGRAND MAGYARORSZAG VILLAMOSSAGI RENDSZEREK ZRT
 Ipartelepi ut 14 pf 10 ; 6600 SZENTES – Hungary

 LEGRAND FRANCE ISERE
 Place du Breuil, 38680 PONT EN ROYANS – France

 BTICINO SPA. (Varese)
 Viale Luigi Borri, 231 ; 21100 VARESE – Italy


 ERP ELBROMPLAST
 Calea Vidrighin, Stan n° 13A ; 300571 TIMISOARA - Romania

References, ratings and main characteristics

Type references	References	Pattern	Actuating	Type of terminals	IP	IK	Characteristics	Specificity
CM26B	0 778 11	6	R	slt	IP55	10	10AX / 250V~	/
	0 778 12	6	R	slt	IP55	10	10AX / 250V~	luminous
	0 778 13	6	R	slt	IP55	10	10AX / 250V~	label holder
	0 778 14	6	R	slt	IP55	10	10AX / 250V~	indicator
PE10V1	0 778 21	7	R	st	IP55	10	10AX / 250V~	/
BI16V1	0 778 22	2	R	st	IP55	10	16AX / 250V~	/
CM26P	0 778 41	6	RM	slt	IP55	10	6A / 250V~	/
	0 778 42	6	RM	slt	IP55	10	6A / 250V~	luminous
	0 778 43	6	RM	slt	IP55	10	6A / 250V~	label holder
	0 778 44	6	RM	slt	IP55	10	6A / 250V~	Indicator

Contact opening (gap)	normal gap
Method of actuating	R = Rocker, RM = Rocker momentary contact
Method of mounting	flush-type Surface-type with box 0 778 90 or 0 778 92
Method of installation	design A
Type of terminals	St = screw type, Slt = screwless terminals

References	Accessories Designation
0 778 66	Blank IP55 IK10
0 802 51	Frame 1 gang
0 802 61	Frame 1 gang with short claws
0 802 52	Frame 2 gang
0 802 53	Frame 3 gang
0 778 51	Cover plate 1 gang
0 778 52	Cover plate; 2 gang; horizontal or vertical; 71mm fixing centres
0 778 53	Cover plate; 3 gang; horizontal or vertical; 71mm fixing centres
0 778 85	Foam joint for cover plate 1 gang
0 778 86	Foam joint for cover plate 2 gang
0 778 87	Foam joint for cover plate 3 gang
0 778 90	Surface-type box 1 gang
0 778 92	Surface-type box 2 gang
0 778 96	Spare cap


 LCIE – Laboratoire Central des Industries Electriques
 33, avenue du Général Leclerc – BP8
 FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr


Date: 06/02/2017

 Signature: **Gilles LEMONNIER**
 Certification Officer