



Accréditation
N°5-0014
Portée
disponible sur
www.cofrac.fr



Ref. Certif. No.

FR 578301

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE
CERTIFICATS D'ESSAIS DES EQUIPEMENTS
ELECTRIQUES (IECEE) METHODE OC

CB TEST CERTIFICATE / CERTIFICAT D'ESSAI OC

Socket-outlet for fixed-electrical installations

LEGRAND FRANCE

128, avenue du Maréchal de Lattre de Tassigny B.P. 523 - 87045 LIMOGES
CEDEX - France

LEGRAND FRANCE

128, avenue du Maréchal de Lattre de Tassigny B.P. 523 - 87045 LIMOGES
CEDEX - France

See annex 1

see annex 2



Series ARTEOR

References of products : see annex 2

References of accessories : see test report n°8700 8-578303

/

PUBLICATION

EDITION

IEC 60884-1:2002 (third edition) +A1:2006

87008-578303, SMT/AP08/H00110, 60048013-548589A



Laboratoire Central des Industries Électriques

33, av du Général Leclerc – BP 8
FR 92266 Fontenay-aux-Roses cedex
www.lcie.fr

Date: 2009-08-24

Signature:

Michel BRENON
Certification Manager





Accréditation
N°5-0014
Portée
disponible sur
www.cofrac.fr



Ref. Certif. No.

FR 578301


Annex 1 : List of Manufacturers and Factories

Socket-outlet for fixed-electrical installations

Factory	Manufacturer
LEGRAND FRANCE 128, avenue du Maréchal de Lattre de Tassigny B.P. 523 - 87045 LIMOGES CEDEX - FRANCE	LEGRAND FRANCE 128, avenue du Maréchal de Lattre de Tassigny B.P. 523 - 87045 LIMOGES CEDEX - FRANCE
LEGRAND BEIJING N°4 Chaoqian Road, Ke Ji Yuan Qu, Chang Ping Distr ict - 102200 BEIJING - CHINA	LEGRAND FRANCE 128, avenue du Maréchal de Lattre de Tassigny B.P. 523 - 87045 LIMOGES CEDEX - FRANCE
LEGRAND (India) Pvt, Ltd Plot No, A-2, MIDC, Malegaon Village SINNAR, District : NASIK - 422113 SINNAR - INDIA	LEGRAND FRANCE 128, avenue du Maréchal de Lattre de Tassigny B.P. 523 - 87045 LIMOGES CEDEX - FRANCE

Additional information, if necessary:
Informations complémentaires, si nécessaire:

Laboratoire Central des Industries Électriques
33,av du Général Leclerc – BP 8
FR 92266 Fontenay-aux-Roses cedex
www.lcie.fr



Date

2009-08-24

Signature

Michel BRENON
Certification Manager



Accréditation
N°5-0014
Portée
disponible sur
www.cofrac.fr



Ref. Certif. No.

FR 578301

Annex 2

ARTEOR SERIES

RATING AND PRINCIPAL CHARACTERISTICS

Bases

References			Characteristics	Function	Specificity
Square					
White	Magnesium	Red			
572021	572521		16A - 250V~	2P+T	
572020	572520		16A - 250V~	2P	
		572466	16A - 250V~	2P+T	tamperproof

CLASSIFICATION

Standard sheet:	I and V (CEE7)
Rated current (A)	16A
Rated voltage (V)	250V~
Degree of protection	IP20 / IP44 with cover plates 575190 / 575190E
Provision for earthing	With or without earthing contact (see above table)
Method of connecting the cable	rewirable
Type of terminals	screw-type
Degree of protection against electric shock	increased protection
Existence of shutters	with shutters
Method of application - mounting	flush-type
Method of installation	design A

Additional information if necessary:
Informations complémentaires (si nécessaire):

Laboratoire Central des Industries Électriques

33, av du Général Leclerc – BP 8
FR 92266 Fontenay-aux-Roses cedex
www.lcie.fr



Date: 2009-08-24

Signature:

Michel BRENON
Certification Manager