

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product

Socket-outlet for fixed-electrical installations

Name and address of the applicant

LEGRAND FRANCE

128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY  
87045 LIMOGES CEDEX - FRANCE

Name and address of the manufacturer

LEGRAND FRANCE

128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY  
87045 LIMOGES CEDEX - FRANCE

Name and address of the factory

See annex

Note: When more than one factory, please report on page 2

☐ Additional Information on page 2

Ratings and principal characteristics

16A, 250V~

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

Series : FORIX

References : 7824x0, 7824x2, 7824x7, 7824x9

Additional information (if necessary may also be reported on page 2)

Supersedes CBTC 625964C dated 30/09/2012. Update further to the evolution of the standard(s) and addition of product references and factory

☐ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60884-1:2002(ed.3) +A1:2006 +A2:2013

As shown in the Test Report Ref. No. which forms part of this Certificate

154280-718072, 113527-625966, 133425-668119

This CB Test Certificate is issued by the National Certification Body

LCIE – Laboratoire Central des Industries Electriques  
33, avenue du Général Leclerc – BP8  
FR 92 266 Fontenay aux Roses Cedex  
[www.lcie.fr](http://www.lcie.fr)

Date: 12/02/2019

Signature:  Didier BOURGES  
Manager of Certification Operations

# ANNEX

## Name and address of the factories:

**MIO CONTO Kft.**  
ELEGE 72-76  
6630 MINTSZENT  
HUNGARY

**LEGRAND (LLC "LEGRAND" ULYANOVSK)**  
30 PROEzd INZHENERNY, 5.1  
432072 ULYANOVSK  
RUSSIAN FEDERATION

## Mechanisms

References	Designation	Characteristics	Specificities
7 824 x0	2P	16A 250V~	Without shutters
7 824 x2	2x2P	16A 250V~	Without shutters
7 824 x7	2P+E	16A 250V~	With shutters
7 824 x9	2x2P+E	16A 250V~	With shutters

X=1 white

X=4 ivory

standard Sheet:	IIIA (2 poles) NF C 61-314 I (2 poles with earthing contact)
rated current (A)	16A
rated voltage (V)	250V
degree of protection	IP20
provision for earthing	See above table
method of connecting the cable	rewirable
type of terminals	screw-type
<b>socket-outlets</b>	
number of socket-outlets	See above table
degree of protection against electric shock	normal protection
existence of shutters	See above table
method of application - mounting	Surface-type
method of installation	design A

## Accessories

References	Designation
7 824 25	Mosaic adaptor
7 824 94	Surface box 4 gang
7 824 95	Blanking plate
7 824 96	Surface box 6 gang



LCIE – Laboratoire Central des Industries Electriques  
33, avenue du Général Leclerc – BP8  
FR 92 266 Fontenay aux Roses Cedex  
[www.lcie.fr](http://www.lcie.fr)

Date: 12/02/2019

Signature: **Didier BOURGES**  
Manager of Certification Operations

