

# CERTIFICATE

Issued to:  
Applicant:  
**Legrand France**  
128, av. du Maréchal-de-Lattre  
87045 Limoges Cedex, France

Manufacturer/Licensee:  
**Legrand France**  
128, av. du Maréchal-de-Lattre  
87045 Limoges Cedex, France

Product(s) : socket-outlets (2-pole)  
Trade name(s) : LEGRAND  
Type(s)/model(s) : 7824x1, 7824x2, 7824x3, 7824x8, 7824x0, 7824y0, 7824y3

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard IEC 60884-1:2002 + A1: 2006, NEN 1020:1987 + A2: 2004
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 900095


DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.


This certificate is issued on: 12 November 2012 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 2158021.01

DEKRA Certification B.V.



drs. G.J. Zoetbrood  
Managing Director



H.L. Schendstok  
Certification Manager

© Integral publication of this certificate is allowed

All testing, inspection, auditing and certification activities of the former KEMA Quality are an integral part of the DEKRA Certification Group.

ACCREDITED BY  
THE DUTCH COUNCIL  
FOR ACCREDITATION





**SPECIFICATION OF THE CERTIFIED PRODUCT****Product data**

product	:	socket-outlets (2-pole)
trade name	:	LEGRAND
types	:	7824x1, 7824x2, 7824x3, 7824x8, 7824x0, 7824y0, 7824y3
method of mounting	:	surface type
cover	:	cover of thermoplastic material
terminals	:	screw terminals
rated current	:	16 A
rated voltage	:	250 V~
markings	:	-tradename, series indication and electrical ratings on the socket-outlet

**Additional information**

the x and y in the type reference will be replaced by a number

as follows:

x=1: white

x=4: ivory

x=7: wood

y=2: white

y=5: ivory

y=8: wood

**Product data - type 7824x1**

earthing	:	with side earthing-contacts
design	:	singular type

**Product data - type 7824x2**

earthing	:	without earthing contact
design	:	two-fold

**Product data - type 7824x3**

earthing	:	with side earthing-contacts
design	:	two-fold

**Product data - type 7824x8**

earthing	:	with side earthing-contacts
design	:	three-fold, safety socket-outlet

**Product data - type 7824x0**

earthing	:	without earthing contact
design	:	singular type

**Product data - type 7824y0**

earthing : with side earthing contacts  
design : singular type, safety socket-outlet

**Product data - type 7824y3**

earthing : with side earthing-contacts  
design : two-fold, safety socket-outlet  
uitvoering : 2-VOUDIG

**TESTS****Test requirements**

IEC 60884-1:2002 + A1:2006  
NEN 1020:1987 + A2:2004

**Test result**

The test results are laid down in DEKRA test file 2158021.01.

**Remarks**

This certificate is also based on the LCIE CB Test Certificate FR-625937B.

**Conclusion**

The examination proved that all test requirements were met.

Tested by : LCIE

Checked by : H.R.M. Barends

A handwritten signature in blue ink, appearing to read "H.R.M. Barends", is written over the text "Checked by : H.R.M. Barends".**Factory locations**

Mio Conto Kft  
Elege 72-76, 6630, Mintszent  
Hungary