



Accréditation
N° 5-0014



Ref. Certif. No.

FR 60046570C

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE
CERTIFICATS D'ESSAIS DES EQUIPEMENTS
ELECTRIQUES (IECEE) METHODE OC

CB TEST CERTIFICATE CERTIFICAT D'ESSAI OC

Product
Produit

Boxes and enclosures for electrical accessories

Name and address of the applicant
Nom et adresse du demandeur

LEGRAND FRANCE

128, avenue du Maréchal de Lattre de Tassigny B.P. 523 -
87045 LIMOGES CEDEX - FRANCE

Name and address of the manufacturer
Nom et adresse du fabricant

See annex

Name and address of the factory
Nom et adresse de l'usine

See annex

Ratings and principal characteristics
Valeurs nominales et caractéristiques principales

Insulating material, flush-type in wall, ceilings, floors non
combustible or combustible, with inlets for plain or corrugated

Trademark (if any)
Marque de fabrique (si elle existe)

LEGRAND

Model / Type Ref
Ref de type

Series BATIBOX
References :see annex page 2

Additional information (if necessary)
Information complémentaire (si nécessaire)

/

PUBLICATION

EDITION

A sample of the product was tested and found
to be in conformity with
Un échantillon de ce produit a été essayé et a été
considéré conforme à la

IEC 60670-1:2002 (first ed)

As shown in the Test Report Ref. No. which forms part
of this Certificate
Comme indiqué dans le Rapport d'essais numéro de
référence qui constitue partie de ce Certificat

Test report n° 60046570-546917B

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme National de Certification



Laboratoire Central des Industries Electriques
33, av du Général Leclerc - BP 8
FR 92266 Fontenay-aux-Roses cedex
www.lcie.fr

Date : 2007-02-19

Signature :

Michel BRENON
Certification Manager



dltr-oc-1.2



Ref. Certif. No.

FR 60046570C

Annex

Factories	Manufacturer
LEGRAND France (2AP) 128, avenue du Maréchal de Lattre de Tassigny B.P. 523 87045 LIMOGES CEDEX - FRANCE	LEGRAND France (2AP) 128, avenue du Maréchal de Lattre de Tassigny B.P. 523 87045 LIMOGES CEDEX - FRANCE
LEGRAND ELECTRICA SA (1645AP) Estrada Da Alagoa, 96 2775-716 CARCAVELOS - PORTUGAL	LEGRAND France (2AP) 128, avenue du Maréchal de Lattre de Tassigny B.P. 523 87045 LIMOGES CEDEX - FRANCE
ELBROMPLAST SC (1644AP) 300571 Calea Vidrighin Stan n° 13A 1900 TIMISOARA - ROUMANIE	LEGRAND France (2AP) 128, avenue du Maréchal de Lattre de Tassigny B.P. 523 87045 LIMOGES CEDEX - FRANCE

Classification

Classification		
Nature of material		Insulating
Method of installation	Flush type	Non combustible walls, ceilings or floors
		Combustible walls, ceilings or floors
	Placement	Suitable for all types of installation except into concrete
Type of inlets (outlets)		With inlets for plain or corrugated conduits
Clamping means		Without clamping means
Minimum and maximum temperatures during installation		-5 °C/ to +60 °C
The provision for fixing accessories to boxes		Boxes supplied with screws

Masonry Batibox boxes

Reference	Number of gang	Depth (mm)	Shape	Distance between centres (mm)
80108 ¹⁾	1	40/30	Round	
80109 ²⁾	1	40/30	Round	
80140	1 module	40	Rectangular	
80149	3 modules	40	Rectangular	
80131 ³⁾	1	30	Square	
80141 ³⁾	1	40	Square	
80151 ³⁾	1	50	Square	
80161 ³⁾	1	60	Square	
80142	2	40	Rectangular	71
80143	3	40	Rectangular	71
80144	4	40	Rectangular	71

¹⁾ cut out and joined back with back with screw ²⁾ cut out and joined back with back without screw ³⁾ joined**Accessories**

Reference	
80199	Anti-plaster screen
80197	Long screw 40mm

**Laboratoire Central des Industries Électriques**

33,av du Général Leclerc – BP 8
FR 92266 Fontenay-aux-Roses cedex
www.lcie.fr

Date: 2007-02-19

Signature:

