

ASSOCIAZIONE PER LA CERTIFICAZIONE DELLE APPARECCHIATURE ELETTRICHE

Via Tito Livio, 5 - 24123 - BERGAMO (Italy)

tel.+390354175244 fax.+390354534662e-mail:acaecert@tin.it



## Certificate of Conformity

LOVAG-Certificate No. IT 06.025

## **Apparatus**

Low voltage swithchgear assembly - 3 phases + neutral - 400 V (U ) -690 V ( $U_{_{\rm I}}$ ) - 6 kV ( $U_{_{\rm imp}}$ ) - 1600 A ( $I_{_{\rm D}}$ ) - 70 kA ( $I_{_{\rm cc}}$ ) - frequency 50Hz

This Certificate applies only to Designation the apparatus tested. The responsibility for conformity of

any apparatus having the same designation with that tested

rests with the manufacturer or

This certificate has been pre-

Objectives and Operating Principles of mutual recognition.

pared according to LOVAG (Low Voltage Agreement Group)

The responsible certification

body as member of LOVAG

Standard(s) following the

applicable.

issues a Certificate of Conformity with the above mentioned

exclusive use of LOVAG Test Instructions wherever

Only integral reproduction of

this Certificate or reproductions

of this page accompanied by any page(s) on which are

stated the tests performed and

the assigned rated characteristics of the apparatus

tested, are permitted without

written permission from the LOVAG Signatory responsible

responsible vendor.

XL3 4000 Arrangement 52

Manufacturer or responsible vendor

Legrand S.A. - 128, Av.du Marèchal-de-Lattre-de-Tassigny - 87045 Limoges Cedex (France)

Tested for: Legrand S.A.

Tested by: ACAE Laboratory II 01

The apparatus, constructed in accordance with the description mentioned in the Test Report listed on this Certificate has been subjected to the series of proving tests in accordance with IEC/EN 60439-1:Ed. 4.1 (2004) and EN 60439-1 (1999)+A1 (2004)

8.2.3.2.3 a) Rated conditional short-circuit current 8.2.3.2.3 b) Rated short-time withstand current 8.2.4.2 Short-circuit strength of the protective circuit

The results are shown in the Test Report in accordance to LOVAG. The values obtained and the general performance are considered to comply with the above Standard(s) and to justify the characteristic assigned by the manufacturer as stated below.

> 400 V (U<sub>o</sub>) Main circuits

- outgoing 70 kA (I<sub>cc</sub>)

- busbars 70 kA  $(I_{cw})^{cc}$  - 154 kA  $(I_{ox})$  - duration 1000 ms

Protective circuit

- 42 kA (I<sub>cw</sub>) - duration: 200 ms

This document includes Report No.: 06.028 Issue Date: 2006.07.07

Responsible Certification Body: ACAE

Mauro Marchi

Authorized Signature

Date: 2006.07.20



Signatory of EA and IAF Mutual Recognition Agreements

