



ASSOCIAZIONE PER LA CERTIFICAZIONE
DELLE APPARECCHIATURE ELETTRICHE

Via Tito Livio, 5 - 24123 - BERGAMO (Italy)

tel. +390354175244 fax: +390354534662 e-mail: acaecert@tin.it



Certificate of Conformity

LOVAG-Certificate No. IT 06.019

Apparatus

Low voltage switchgear assembly - 3 phases + neutral - 400 V (U_n) -
690 V (U_i) - 6 kV (U_{imp}) - 800 A (I_n) - 50 kA (I_{cc}) - frequency 50/60Hz

Designation

XL3 800 Arrangement 15

Manufacturer or responsible vendor

Legrand S.A. - 128, Av. du Maréchal-de-Lattre-de-Tassigny - 87045 Limoges
Cedex (France)

Tested for: Legrand S.A.

Tested by: ACAE Laboratory IB 01

The apparatus, constructed in accordance with the description mentioned in
the Test Report listed on this Certificate has been subjected to the series of
proving tests in accordance with IEC/EN 60439-1:1999; amendment 1:2004

8.2.1 Verification of temperature-rise limits using current on all apparatus

The results are shown in the Test Report in accordance to LOVAG. The values
obtained and the general performance are considered to comply with the
above Standard(s) and to justify the characteristic assigned by the manufacturer
as stated below.

Incoming circuit 800 A (I_n)
Diversity factor 0,81

Outgoing circuit 250 A (I_n)
Diversity factor 0,65

This document includes Report No.: 06.043
Issue Date: 2006.07.07

Responsible Certification Body: ACAE



PRD N°070B

Signatory of EA and IAF Mutual Recognition Agreements

Mauro Marchi

Mauro Marchi

Authorized Signature

Date: 2006.07.20

