



Ref. Certif. No.

ES1853-M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB
SCHEMESYSTEME CEI D'ACCEPTATION MUTUELLE DE CERTIFICATS
D'ESSAIS DES EQUIPEMENTS ELECTRIQUES (IECEE) METHODE
OC

CB TEST CERTIFICATE CERTIFICAT D'ESSAI OC

Product
Produit

FLUORESCENT LUMINAIRE FOR EMERGENCY LIGHTING

Name and address of the applicant
Nom et adresse du demandeurLEGRAND GROUP ESPAÑA, S.L.
CL HIERRO, 56
28850 TORREJON DE ARDOZ (Madrid - Spain)Name and address of the manufacturer
Nom et adresse du fabricant

SAME AS ABOVE

Name and address of the factory
Nom et adresse de l'usine

SAME AS ABOVE

Note: when more than one factory, please report on page 2
Note: lorsque il y plus d'une usine, veuillez utiliser la 2^{ème} page☐ Additional Information on page 2Ratings and principal characteristics
Valeurs nominales et caractéristiques principales

See Annex

Trademark (if any)
Marque de fabrique (si elle existe)

LEGRAND

Type of Manufacturer's Testing Laboratories used
Type de programme du laboratoire d'essais constructeur

-

Model / Type Ref.
Ref. de type

See Annex

Additional information (if necessary may also be reported on
page 2)
Les informations complémentaires (si nécessaire, peuvent être
indiqués sur la 2^{ème} page)☐ Additional Information on page 2A sample of the product was tested and found
to be in conformity with
Un échantillon de ce produit a été essayé et a été
considéré conforme à laIEC 60598-1:2014
IEC 60598-2-22:2014As shown in the Test Report Ref. No. which forms part of this
Certificate
Comme indiqué dans le Rapport d'essais numéro de référence
qui constitue partie de ce Certificat

2017030094B1

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme National de CertificationAENOR INTERNACIONAL S.A.U.
Cl Génova, 6
ES-28004 MADRID (SPAIN)

Date: 2018-03-16

Signature: Rafael GARCÍA MEIRO
Chief Executive Officer

ANNEX TO CB CERTIFICATE N° ES1853-M1

CERTIFIED REFERENCES AND THEIR MAIN RATINGS

Product: FLUORESCENT LUMINAIRE FOR EMERGENCY LIGHTING

Trade Mark: LEGRAND

Type reference	No. lamps x rated wattage	Rated lumen output	Rated duration	Additional information
066000	Lamp 1 x 8W	140 lm	1h	Non maintained; Ni-Cd 3,6 V 1,5 Ah 3 cells
066001	Lamp 1 x 8W	140 lm - emergency	1h	Maintained; Ni-Cd 3,6 V 1,5 Ah 3 cells
066002	Lamp 2 x 8W	140 lm - emergency	1h	Combined non-maintained; Ni-Cd 3,6 V 1,5 Ah 3 cells
066003	Lamp 1 x 8W	110 lm	3h	Non maintained; Ni-Cd 6,0 V 1,5 Ah 5 cells
066004	Lamp 1 x 8W	110 lm - emergency	3h	Maintained; Ni-Cd 6,0 V 1,5 Ah 5 cells
066005	Lamp 2 x 8W	110 lm - emergency	3h	Combined non-maintained; Ni-Cd 6,0 V 1,5 Ah 5 cells

Rated voltage and frequency

Type of lamps and lampholder

IP degree of protection

Means for power connection

Classif. per holding surface material

Protection against electric shocks (class)

230 V~; 50/60 Hz

Fluorescent; lampholder G5

IP 42; IK 07

Terminals

Suitable for normally flammable surfaces

Class II