



ASSOCIAZIONE PER LA CERTIFICAZIONE
DELLE APPARECCHIATURE ELETTRICHE

Via Tito Livio, 5 – 24123 – BERGAMO (Italy)
Tel. +390354175244 fax. +390354534662 e-mail: acaec@acaecert.it



Certificate of Conformity

LOVAG-Certificate No. IT 14.021

This certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designation with that tested rests with the manufacturer or responsible vendor.

This certificate has been prepared according to LOVAG (Low Voltage Agreement Group) Objectives and Operating Principles of mutual recognition.

The responsible certification body as member of LOVAG issues a Certificate of Conformity with the above mentioned Standard(s) following the exclusive use of LOVAG Test Instructions wherever applicable.

Only integral reproduction of this Certificate or reproductions of this page accompanied by any page(s) on which are stated the tests performed and the assigned rated characteristics of the apparatus Tested, are permitted without written permission from the LOVAG Signatory responsible for this Certificate.

Apparatus Four poles modular circuit breaker
415V (U_e) – 63A (I_n) – 50kA at 415V (I_{cu}) 50/60Hz
37,5kA at 415V (I_{cs})

Designation DX³ 63A 50kA curve “C” 4P

Manufacturer or responsible vendor:
Legrand S.n.c. -128, Av. du Maréchal-de-Lattre-de-Tassigny-
87045 Limoges Cedex (France)

Tested for: Legrand S.n.c.

Tested by: ACAE Laboratory IB 01

The apparatus, constructed in accordance with the description mentioned in the Test Report listed on this Certificate has been subjected to the series of proving tests in accordance with
Standard IEC 60947-2: Ed.4.1 (2013-01)+A1 (2009-07)+A2 (2013-01)
EN 60947-2: (2006-08)+ A1 (2009-07)+A2 (2013-01)
Sequence II and III

The results are shown in the Test Report in accordance to LOVAG. The values obtained and the general performance are considered to comply with the above Standard(s) and to justify the characteristics assigned by the manufacturer as stated in below.

50kA at 415V (I_{cu})
37,5kA at 415V (I_{cs})

This document includes Test report No.: 139
Issue date: 2014.03.14

Responsible Certification Body : ACAE
Virginio Scarioni



PRD N°070B
Signatory of EA, IAF and ILAC
Mutual Recognition Agreements

Authorized signature

Date: 2014.03.25