



ASSOCIAZIONE PER LA CERTIFICAZIONE
DELLE APPARECCHIATURE ELETTRICHE



V.le delle Brigate Partigiane 6/21 - 16129 - GENOVA (Italy)

tel. +10/565197 fax. +10/5848607 e-mail: acaecert@tin.it

Certificate of Conformity

LOVAG-Certificate No. IT 98.044

Apparatus

Moulded-case, three pole, air-break, independent operation circuit-breakers
Frame size 250 A - 690 V (U_n) - 50/60 Hz - with over-current thermal and
instantaneous releases:

$$I_n = 63; 100; 160; 250 \text{ A}$$

Designation

DPX 250

Manufacturer or responsible vendor

LEGRAND - 128, av. Du Maréchal-de-Lattre-de-Tassigny - 87045 Limoges
Cedex (France)

Tested for: LEGRAND - 128, av. Du Maréchal-de-Lattre-de-Tassigny -
87045 Limoges Cedex (France)

Tested by: ACAE Laboratories IB.01

The apparatus, constructed in accordance with the description mentioned in
the Test Report listed on this Certificate has been subjected to the series of
proving tests in accordance with IEC 947-2 (1995 - 12) and Corrigendum
(1997); EN 60947-2 (1996).

The results are shown in the Test Report in accordance to LOVAG. The values
obtained and the general performance are considered to comply with the
above Standard(s) and to justify the characteristic assigned by the manufacturer
as stated below.

Utilization category A - a.c. 50/60 Hz.

Test sequence II ($I_{cu} = I_{cs}$)


$$U_n = 400 \text{ V}$$

$$I_{cs} = I_{cu} = 36 \text{ kA}$$

This document includes Report No.: 98.244/T01

Issue Date: 1998.10.20

Responsible Certification Body



Authorized Signature

Date: 1998.12.02

This Certificate applies only to
the apparatus tested. The
responsibility for conformity of
any apparatus having the same
designation with that tested
rests with the manufacturer or
responsible vendor.

This certificate has been pre-
pared according to LOVAG
(Low Voltage Agreement Group)
Objectives and Operating Prin-
ciples of mutual recognition.
The responsible certification
body as member of LOVAG
issues a Certificate of Conform-
ity with the above mentioned
Standard(s) following the
exclusive use of LOVAG Test
Instructions wherever
applicable.

Only integral reproduction of
this Certificate or reproductions
of this page accompanied by
any page(s) on which are
stated the tests performed and
the assigned rated charac-
teristics of the apparatus
tested, are permitted without
written permission from the
LOVAG Signatory responsible
for this Certificate.