

Ref. Certif. No.

FR\_706409

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME				
CB TEST CERTIFICATE				
Product	Fixed socket-outlet Socket-outlets for fixed installations			
Name and address of the applicant	LEGRAND MAGYARORSZAG VILLAMOSSAGI RENDSZEREK ZRt IPARTELEPI UT 14 PF 10 6600 SZENTES - HUNGARY			
Name and address of the manufacturer	LEGRAND MAGYARORSZAG VILLAMOSSAGI RENDSZEREK ZRt IPARTELEPI UT 14 PF 10 6600 SZENTES - HUNGARY			
Name and address of the factory	LEGRAND MAGYARORSZAG VILLAMOSSAGI RENDSZEREK ZRt IPARTELEPI UT 14 PF 10 6600 SZENTES - HUNGARY			
Note: When more than one factory, please report on page 2	Additional Information on page 2			
Ratings and principal characteristics	13A, 250V See Annex			
Trademark (if any)	() legrand			
Customer's Testing Facility (CTF) Stage used	/			
Model / Type Ref.	077505, 678148, 678198, 678240, 678241, 678242			
Additional information (if necessary may also be reported on page 2)	Additional Information on page 2			
A sample of the product was tested and found to be in conformity with	IEC 60884-1:2002+A1:2006 +A2:2013			
As shown in the Test Report Ref. No. which forms part of this Certificate	ARFH-19MY0491ACSHP			
This CB Test Certificate is issued by the National Certification Body				
LCIE – Laboratoire Central des Industries Electriques 33, avenue du Général Leclerc – BP8 FR 92 266 Fontenay www.lcie.fr Date: 22/07/2019 LCIE – Laboratoire Central des Industries Electriques ALBORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES S.A.S au capital de 15.745.984 6 RCS Nanterre B 408 361 174 33 avenue du Général Jernesture: Julien Gauthier F - 92266 FONTENAY AUX ROSES Certification Officer				



FR\_706409

## ANNEX

## References, ratings and main characteristics:

Reference	Range*	Description	Color of enclosure	with cover plate	with support frame
077505	MOSAIC	2P+E 13A British Standard unswitched 1 gang	White	678011	678000
678148	MOSAIC	2P+E 13A British Standard unswitched 1 gang Antimicrobial	White	678026	678000
678198	MOSAIC	2P+E 13A British Standard unswitched 1 gang	Alu	678031	678000
678240	MOSAIC	2P+E 13A British Standard unswitched 1 gang	Red cover with white cover plate	678011	678000
678241	MOSAIC	2P+E 13A British Standard unswitched 1 gang	Green cover with white cover plate	678011	678000
678242	MOSAIC	2P+E 13A British Standard unswitched 1 gang	Orange cover with white cover plate	678011	678000

\* The "range" denotes applicant's categorization.

standard Sheet:	BS 1363-2
rated current (A)	13A
rated voltage (V)	250V
degree of protection	IP20
provision for earthing	with earthing contact
method of connecting the cable	rewirable
type of terminals	screw-type
colour	White, Alu, Red cover with white cover plate, Green cover with white cover plate, Orange cover with white cover plate
socket-outlets	
multiple socket-outlets number of socket-outlets	13A: 1
degree of protection against electric shock	normal protection
existence of shutters	with shutters
method of application - mounting	flush-type
method of installation	design A



LCIE – Laboratoire Central des Industries Electriques 33, avenue du Général Leclerc – BP8 FR 92 266 Fontenay aux Roses Cedex www.lcie.fr Industries electriques

Date: 22/07/2019



INDUSTRIES ELECTRIQUES S.A.S au capital de 15.745.984 ¢ RCS Nanterre B 408 363 174 L C I E 33 avenue du Gén**Gigaqueture: Julien Gauthier** ` F - 92266 FONTENAY AUX ROSES Certification Officer