

DECLARATION DES PERFORMANCES N° 0333-CPD-075212

Nous, URA
5, rue Jean Nicot – 93691 PANTIN – France

Déclarons que le produit : DM d'ALARME ADR à membrane + IA mécanique
réf. 340000

Satisfait aux dispositions du règlement du Conseil 305/2011/UE du 9 mars 2011 "Règlement Produits Construction - RPC" - Le système d'évaluation et de vérification de la constance des performances du produit de construction, conformément à l'annexe V est : système 1.

Ces dispositions sont assurées pour le règlement 305/2011/UE par la conformité à la (aux) norme(s) suivante(s) :

- EN 54-11:2001 + A1: 2006,

AFNOR Certification, notifié n°0333, a réalisé la détermination du produit type. La conformité est attestée par le certificat de constance des performances n° 0333-CPR-075212-1.

Produit : Système de détection automatique d'incendie – Déclencheurs manuels d'alarme.

Usage prévu : Déclencheurs manuels intégrés dans les systèmes de détection et d'alarme incendie installés à l'intérieur ou à l'extérieur d'un bâtiment.

PERFORMANCES DECLAREES


Caractéristiques essentielles	Performances	Spécification technique harmonisée
Conditions nominales d'activation / Sensibilité et performances dans des conditions d'incendie	Conforme	EN 54-11: 2001+ A1:2006 art: 4.3.2, 4.4, 4.7.1, 4.7.4, 5.2, 5.3
Fiabilité de fonctionnement	Conforme	EN 54-11: 2001+ A1:2006 art: 4.2, 4.3.1, 4.5, 4.6, 4.7.2, 4.7.3, 4.7.5, 4.8, 5.4, 5.5
Durabilité de la fiabilité de fonctionnement, résistance à la température	Conforme	EN 54-11: 2001+ A1:2006 art: 5.7, 5.8*, 5.9 *Dispositifs extérieurs uniquement
Durabilité de la fiabilité de fonctionnement, résistance aux vibrations	Conforme	EN 54-11: 2001+ A1:2006 art: 5.14, 5.15, 5.16, 5.17
Durabilité de la fiabilité de fonctionnement, résistance à l'humidité	Conforme	EN 54-11: 2001+ A1:2006 art: 5.10, 5.11*, 5.12, 5.19* *Dispositifs extérieurs uniquement
Durabilité de la fiabilité de fonctionnement, résistance à la corrosion	Conforme	EN 54-11: 2001+ A1:2006 art: 5.11, 5.13
Durabilité de la fiabilité de fonctionnement, stabilité électrique	Conforme	EN 54-11: 2001+ A1:2006 art: 5.6, 5.18* * Dispositifs avec composants électroniques actifs uniquement

La présente déclaration est sous la seule responsabilité de Legrand France SNC.

A Pau,
Le 02 Juillet 2018

Pascal STUTZ,
Directeur SBU Systèmes du bâtiment

Signature





DECLARATION OF PERFORMANCES No. 0333-CPD-075212

We, URA
5, rue Jean Nicot – 93691 PANTIN – France

Hereby declare that the following product: Red Manual call point of alarm with membrane + IA ref. 340000

satisfy the provisions of Council Regulation 305/2011/UE dated March 9, 2011 "Construction Products Regulation (CPR)" - System of assessment and verification of constancy of performance of the construction product as set out in Annex V is : System 1.

These provisions are ensured for Regulation 305/2011/UE by conformity to the following standard(s):

- EN 54-11 : 2001 + A1: 2006,
AFNOR CERTIFICATION, notified No.0333, performed the determination of the typical product. The conformity is attested by the certificate of constancy of performances No. **0333-CPD-075212-1**.

Product: Fire detection and alarm system – Manual call points.

Planned use: Manual releases integrated in the systems of detection and alarm sets fire to installed inside or outside a building.

DECLARED PERFORMANCES

Essential characteristics	Performances	Harmonized technical specification
Nominal activation conditions / Sensitivity and Performance under fire conditions	Pass	EN 54-11: 2001+ A1:2006 art: 4.3.2, 4.4, 4.7.1, 4.7.4, 5.2, 5.3
Operational reliability	Pass	EN 54-11: 2001+ A1:2006 art: 4.2, 4.3.1, 4.5, 4.6, 4.7.2, 4.7.3, 4.7.5, 4.8, 5.4, 5.5
Durability of operational reliability, temperature resistance	Pass	EN 54-11: 2001+ A1:2006 art: 5.7, 5.8*, 5.9 *For outdoor devices only
Durability of operational reliability: vibration resistance	Pass	EN 54-11: 2001+ A1:2006 art: 5.14, 5.15, 5.16, 5.17
Durability of operational reliability: humidity resistance	Pass	EN 54-11: 2001+ A1:2006 art: 5.10, 5.11*, 5.12, 5.19* *For outdoor devices only
Durability of operational reliability: corrosion resistance	Pass	EN 54-11: 2001+ A1:2006 art: 5.11, 5.13
Durability of operational reliability: electrical stability	Pass	EN 54-11: 2001+ A1:2006 art: 5.6, 5.18* *For devices with active electronic components only

The present declaration is solo responsibility of Legrand France SNC.

Signed at Pau,
On July 2nd, 2018

Pascal STUTZ,
Building System SBU Manager

Signature