



Accréditation
N°5-0014
Portée
disponible sur
www.cofrac.fr



Ref. Certif. No.

FR 593476

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE
CERTIFICATS D'ESSAIS DES EQUIPEMENTS
ELECTRIQUES (IECEE) METHODE OC

CB TEST CERTIFICATE / CERTIFICAT D'ESSAI OC

Product
Description

SOCKET-OUTLET

Manufacturer's name and address

LEGRAND FRANCE

128, avenue du Maréchal de Lattre de Tassigny B.P. 523 - 87045 LIMOGES
CEDEX - France

Manufacturer's name and address

LEGRAND FRANCE

128, avenue du Maréchal de Lattre de Tassigny B.P. 523 - 87045 LIMOGES
CEDEX - France

Manufacturer's name and address

LEGRAND FRANCE

128, avenue du Maréchal de Lattre de Tassigny B.P. 523 - 87045 LIMOGES
CEDEX - France

Manufacturer's name and address

16A, 250V~, 2P+T/2P+E

Manufacturer's name and address

legrand®

Manufacturer's name and address

Gamme / Series MOSAIC
Référence / Reference : 77231

Manufacturer's name and address

Voir annexe 1 / See annex 1

Manufacturer's name and address

PUBLICATION

EDITION

IEC 60884-1:2002 (third edition) +A1:2006

Manufacturer's name and address

Rapport d'essai / Test report n°97303-593477

Manufacturer's name and address

National de Certification




Laboratoire Central des Industries Électriques

33, av du Général Leclerc – BP 8
FR 92266 Fontenay-aux-Roses cedex
www.lcie.fr

Date

2010-03-16

Signature





Accréditation
N°5-0014
Portée
disponible sur
www.cofrac.fr



Ref. Certif. No.

FR 593476

Annex 1

RATING AND PRINCIPAL CHARACTERISTICS

Easy to handle socket-outlet of Mosaic series: reference 77231

CLASSIFICATION

standard Sheet:	III (CEE 7)
rated current (A)	16A
rated voltage (V)	250V
degree of protection	IP20
provision for earthing	with earthing contact
method of connecting the cable	rewirable
type of terminals	screwless (rigid and flexible)
colour	white
degree of protection against electric shock	normal protection increased protection
existence of shutters	with shutters
method of application - mounting	flush-type
method of installation	design A

Additional information, if necessary:
Informations complémentaires, si nécessaire:

Laboratoire Central des Industries Électriques

33, av du Général Leclerc – BP 8
FR 92266 Fontenay-aux-Roses cedex
www.lcie.fr



Date

2010-03-16

Signature

Jean-François BRUEL
Certification Officer

