



Fair  
Trading

File Ref: NSW28427  
Contact: Admin Clerk  
Telephone: 02 9895 0722

Mr Jeremy Pettett  
LEGRAND AUSTRALIA PTY LTD  
PO Box 139  
HOXTON PARK NSW 2171

Dear Sir/Madam

CERTIFICATE OF APPROVAL: NSW28427 AND MODIFICATION/S

Residual Current Device

Please find enclosed a Certificate of Approval and addendum as sought by your application.

Articles of the approved type may now be marketed, provided they are marked with the mark (or alternate approval marks) shown on the Certificate.

THE APPROVAL EXPIRES ON THE DATE SHOWN ON THE CERTIFICATE unless it is renewed, extended, suspended or cancelled.

Yours faithfully,

28 January 2021

For Secretary, Department of Customer Service



Fair  
Trading

# Certificate of Approval Declared Article

Pursuant to Section 16 (1) of the Gas and Electricity  
(Consumer Safety) Act 2017

**Certificate Number: NSW28427**

<b>Issued to:</b>	LEGRAND AUSTRALIA PTY LTD
<b>Class of Article:</b>	Residual Current Device
<b>Description of Article:</b>	Residual Current Device [Two-pole (1P + N), functionally independent, Type 'A', residual current device with integral overcurrent protection (RCBO) with an associated Arc Fault Detection Device]
<b>Trade Name or Mark:</b>	'Legrand'
<b>Ratings:</b>	<b>Volts: -</b> <b>Watts:</b> <b>Amperes: -</b> <b>Hertz: 50 Hz</b>  <b>Other Name Plate Particulars:</b> Rated Voltage: 230V - 240V; 50Hz Rated Current: 6A Instantaneous Tripping Characteristic: Curve 'C' Rated Residual Operating Current: 30mA Rated Interrupting Capacity: 10,000A
<b>Type Reference Code:</b>	415964
<b>Examined for Compliance With:</b>	AS/NZS 61009.1 : 2015; IEC 62606 : 2013 A1
<b>Approval Mark:</b>	Each electrical article of the abovementioned type shall be marked with Approval Number NSW28427 or approved alternate mark
<b>Date of Approval:</b>	21/01/2021
<b>Approval Expires:</b>	21/01/2026 <i>unless suspended, cancelled, renewed or extended</i>



28 January 2021



On behalf of the Secretary, Department of Customer Service

For current information regarding currency of certificate, refer to the Fair Trading Website



Fair  
Trading

Ref: NSW28427/1

**ADDENDUM TO CERTIFICATE OF APPROVAL: NSW28427**  
**Particulars of Modification(s)**

The addition of the following:-

- (a) Model No.415965 being similar to Model No. 415964 except for a current rating of 10A in lieu of 6A.
- (b) Model No. 415966 being similar to Model No. 415964 except for a current rating of 13A in lieu of 6A.
- (c) Model No. 415967 being similar to Model No. 415964 except for a current rating of 16A in lieu of 6A.
- (d) Model No. 415968 being similar to Model No. 415964 except for current rating of 20A in lieu of 6A.
- (e) Model No. 415955 being similar to Model No. 415964 except for 6A Curve B in lieu of 6A Curve C.
- (f) Model No. 415956 being similar to Model No. 415955 except for current rating of 10A in lieu of 6A.
- (g) Model No. 415957 being similar to Model No. 415955 except for current rating of 13A in lieu of 6A.
- (h) Model No. 415958 being similar to Model No. 415955 except for a current rating of 16A in lieu of 6A.

This certificate will expire on 21/01/2026

Approved pursuant to Clause 15 (1) of the Gas and Electricity (Consumer Safety) Regulation 2018:

21 January 2021

 28 January 2021

For Secretary, Department of Customer Service