

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Empty enclosures for low-voltage switchgear and controlgear assemblies

Name and address of the applicant

LEGRAND FRANCE
6, Paul Nouel, 76770 MALAUNAY - France

Name and address of the manufacturer

LEGRAND FRANCE
6, Paul Nouel, 76770 MALAUNAY - France

Name and address of the factory

OTIMA
Z.I. de l'Aumallerie 9 rue Henri Bequerel , 35133 LA SELLE EN LUITRE - France

Note: When more than one factory, please report on page 2

 Additional Information on page 2

Ratings and principal characteristics

See annex

Trademark (if any)

LEGRAND

Customer's Testing Facility (CTF) Stage used

CTF2

Model / Type Ref.

Series Atlantic Inox
References: 0 352 34, 0 352 36, 0 352 38, 0 358 39

Additional information (if necessary may also be reported on page 2)

/
 Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 62208:2011(ed.2)

As shown in the Test Report Ref. No. which forms part of this Certificate

145276-694831

This CB Test Certificate is issued by the National Certification Body

LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.frLABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES
S.A.S au capital de 13745084 €
RCS Nanterre 8408363174
33 Avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSES

Date: 16/02/2017

Signature: **Jean-François BRUEL**
Certification Officer

ANNEX 1


REFERENCES, MAINS CHARACTERISTICS

References	Type	Protection degrees	Sizes (mm)	Door lock
0 352 34	stainless steel cabinet 304L	IP66/69, IK 10	400x300x200	1
0 352 36	stainless steel cabinet 304L	IP66/69, IK 10	600x400x250	2
0 352 38	stainless steel cabinet 304L	IP66/69, IK 10	800x600x300	2
0 352 39	stainless steel cabinet 304L	IP 66/69, IK10	1000x800x300	2

Type of material	metallic
Method of fixing	Floor standing / wall mounting
Intended location	Outdoor



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr



Date: 16/02/2017

Signature: **Jean-François BRUEL**
Certification Officer