

DECLARATION DES PERFORMANCES

N° 0333-CPD-075323

Nous, **LEGRAND France SNC**

128, Avenue de Lattre-de-Tassigny - F 87 045 LIMOGES Cedex – France

Déclarons que le produit : DSAF/DSNA - DAGS 90 dB avec flash encastré
réf URA 367211

Satisfait aux dispositions du règlement du Conseil 305/2011/UE du 9 mars 2011 "Règlement Produits Construction - RPC" - Le système d'évaluation et de vérification de la constance des performances du produit de construction, conformément à l'annexe V est : système 1.

Ces dispositions sont assurées pour le règlement 305/2011/UE par la conformité à la (aux) norme(s) suivante(s) :

- EN 54-3 : 2002,

AFNOR Certification, notifié n°0333, a réalisé la détermination du produit type. La conformité est attestée par le certificat de constance des performances n° **0333-CPR-075323-1**.

Produit: Système de détection et d'alarme incendie – Dispositifs sonores d'alarme feu.

Usage prévu : Dispositifs d'alarme feu utilisés dans les systèmes de détection d'incendie pour émettre un signal d'alarme incendie vers les occupants d'un bâtiment.

PERFORMANCES DECLAREES

Caractéristiques essentielles	Performances	Spécification technique harmonisée
Fiabilité de fonctionnement	Conforme	EN 54-3: 2002 art: 4.4, 4.5, 4.6, 5.4, 5.17
Performances dans des conditions d'incendie	Conforme	EN 54-3: 2002 art: 4.2, 4.3, 5.2, 5.3
Durabilité de la fiabilité de fonctionnement, résistance à la température	Conforme	EN 54-3: 2002 art: 5.5, 5.6*, 5.7 *Dispositifs extérieurs uniquement
Durabilité de la fiabilité de fonctionnement, résistance aux vibrations	Conforme	EN 54-3: 2002 art: 5.12, 5.13, 5.14, 5.15
Durabilité de la fiabilité de fonctionnement, résistance à l'humidité	Conforme	EN 54-3: 2002 art: 5.8, 5.9, 5.10*, 5.17 *Dispositifs extérieurs uniquement
Durabilité de la fiabilité de fonctionnement, résistance à la corrosion	Conforme	EN 54-3: 2002 art: 5.11
Durabilité de la fiabilité de fonctionnement, stabilité électrique	Conforme	EN 54-3: 2002 art: 5.16* *Dispositifs comportant des composants électroniques actifs uniquement

Cette présente déclaration est sous la seule responsabilité de LEGRAND France SNC.

A Pau,
Le 26 janvier 2017

Danilo BERNASCONI,
Directeur R&D Système du bâtiment

Signature



DECLARATION OF PERFORMANCES No. 0333-CPD-075323

We, LEGRAND France SNC

128, Avenue de Lattre-de-Tassigny - F 87 045 LIMOGES Cedex – France

Hereby declare that the following product: Fire alarm device – Sounder 90 dB with flash
ref URA 367211

satisfy the provisions of Council Regulation 305/2011/UE dated March 9, 2011 "Construction Products Regulation (CPR)" - System of assessment and verification of constancy of performance of the construction product as set out in Annex V is : System 1.

These provisions are ensured for Regulation 305/2011/UE by conformity to the following standard(s):

- EN 54-3 : 2002,

AFNOR Certification, notified No.0333, performed the determination of the typical product. The conformity is attested by the certificate of constancy of performances No. **0333-CPR-075323-1**.

Product: Fire detection and alarm system – Fire alarm devices – Sounders.

Planned use : Warning devices fire used in the systems of detection of fire to emit an alarm sets fire to towards the occupants of a building.

DECLARED PERFORMANCES

Essential characteristics	Performances	Harmonized technical specification
Operational reliability	Pass	EN 54-3: 2002 art: 4.4, 4.5, 4.6, 5.4, 5.17
Performance under fire condition	Pass	EN 54-3: 2002 art: 4.2, 4.3, 5.2, 5.3
Durability of operational reliability, temperature resistance	Pass	EN 54-3: 2002 art: 5.5, 5.6*, 5.7 *For outdoor devices only
Durability of operational reliability: vibration resistance	Pass	EN 54-3: 2002 art: 5.12, 5.13, 5.14, 5.15
Durability of operational reliability: humidity resistance	Pass	EN 54-3: 2002 art: 5.8, 5.9, 5.10*, 5.17 *For outdoor devices only
Durability of operational reliability: corrosion resistance	Pass	EN 54-3: 2002 art: 5.11
Durability of operational reliability; electrical stability	Pass	EN 54-3: 2002 art: 5.16* *For devices with active electronic components only

The presente declaration is solo responsibility of LEGRAND France SNC.

Signed at Pau,
On January 26th, 2017

Danilo BERNASCONI,
Building System R&D Manager

Signature

