



**Fair
Trading**


Certificate of Approval Declared Article

Pursuant to Electricity (Consumer Safety) Act 2004

Certificate Number: *NSW28151*

Issued to:	LEGRAND AUSTRALIA PTY LTD
Class of Article:	Miniature Overcurrent Circuit Breaker
Description of Article:	Miniature Circuit Breaker with AFD (arc fault detection) Function (AFDD comprising an AFD unit and a MCB with screw terminals, 1P+N, curve C tripping, Icn=6kA, housed in thermoplastic enclosure, DIN rail mounted.)
Trade Name or Mark:	Legrand
Ratings:	Volts: 230Vac Watts: Amperes: 10A Hertz: 50 Hz Other Name Plate Particulars:
Type Reference Code:	415929
Examined for Compliance With:	AS/NZS 60898.1:2004 & IEC 62606:2013
Approval Mark:	Each electrical article of the abovementioned type shall be marked with Approval Number NSW28151 or approved alternate mark.
Date of Approval:	17/06/2019
Approval Expires:	17/06/2024 <i>unless suspended, cancelled, renewed or extended.</i>




On behalf of the Commissioner for Fair Trading

For current information regarding currency of certificate, refer to the Fair Trading Website



**Fair
Trading**

Ref: NSW28151/1

**ADDENDUM TO CERTIFICATE OF APPROVAL: NSW28151
Particulars of Modification(s)**

Model 415930 is similar to approved Model 415929 except for rating of 13A;
Model 415931 is similar to approved Model 415929 except for rating of 16A;
Model 415932 is similar to approved Model 415929 except for rating of 20A;
Model 415920 is similar to approved Model 415929 except for Curve B In lieu of Curve C;
Model 415921 is similar to Model 415920 except for rating of 13A;
Model 415922 is similar to Model 415920 except for rating of 16A.

This certificate will expire on 17/06/2024

Approved: 18 June 2019


For Commissioner for Fair Trading



Fair
Trading

File Ref: NSW28151/2
Contact: Admin Clerk
Telephone: 02 9895 0722

Mr Jeremy Pettett
LEGRAND AUSTRALIA PTY LTD
PO Box 139
HOXTON PARK NSW 2171

Dear Sir/Madam

MODIFICATION TO CERTIFICATE OF APPROVAL: NSW28151

Miniature Overcurrent Circuit Breaker

Please find enclosed an addendum to the certificate as sought in your application.

Yours faithfully,

2 September 2020

For Secretary, Department of Customer Service



Fair
Trading

Ref: NSW28151/2

ADDENDUM TO CERTIFICATE OF APPROVAL: NSW28151 Particulars of Modification(s)

B Curve 6kA Model 415919 is similar to approved Model 415929 except for being rated 6A;

C Curve 6kA Model 415928 is similar to approved Model 415920 except for being rated 6A;

General modification - The AFD unit of all models may be alternatively incorporate changes to earth arc faults circuit, internal wire location and case design, and AFD unit terminals.

This certificate will expire on 17/06/2024

Approved pursuant to Clause 15 (1) of the Gas and Electricity (Consumer Safety) Regulation 2018:

2 September 2020

For Secretary, Department of Customer Service



Fair
Trading

File Ref: NSW28151/3
Contact: Admin Clerk
Telephone: 02 9895 0722

Mr Jeremy Pettett
LEGRAND AUSTRALIA PTY LTD
PO Box 139
HOXTON PARK NSW 2171

Dear Sir/Madam

MODIFICATION TO CERTIFICATE OF APPROVAL: NSW28151

Miniature Overcurrent Circuit Breaker

Please find enclosed an addendum to the certificate as sought in your application.

Yours faithfully,

30 October 2020

For Secretary, Department of Customer Service



Fair
Trading

Ref: NSW28151/3

ADDENDUM TO CERTIFICATE OF APPROVAL: NSW28151
Particulars of Modification(s)

407728 being similar to 415931 except without AFDD function. Operates as an MCB only.

This certificate will expire on 17/06/2024

Approved pursuant to Clause 15 (1) of the Gas and Electricity (Consumer Safety) Regulation 2018:

30 October 2020

For Secretary, Department of Customer Service